

## CLANTON WATER DEPARTMENT

CLANTON, AL | PWSID: AL0000213 | Population served: 13,500

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS severely exceeds the federal limit at 5.38x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	21.5	4.0	5.38	<b>EXCEEDS</b>
PFOA	19.5	4.0	4.88	<b>EXCEEDS</b>
PFHxS	3.3	10.0	0.33	Below limit
PFBS	62.8	-	-	No federal limit
PFPeA	22.5	-	-	No federal limit
PFHxA	14.5	-	-	No federal limit
PFBA	9.7	-	-	No federal limit
PFHpA	5.1	-	-	No federal limit

### What This Means

This water system serves 13,500 residents in CLANTON. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans