

## COLLINSVILLE WATER WORKS

COLLINSVILLE, AL | PWSID: AL0000506 | Population served: 3,945  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOA severely exceeds the federal limit at 7.94x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	31.8	4.0	7.94	<b>EXCEEDS</b>
PFOS	5.8	4.0	1.46	<b>EXCEEDS</b>
PFHpA	6.3	-	-	No federal limit
PFHxA	4.9	-	-	No federal limit
PFPeA	4.5	-	-	No federal limit

### What This Means

This water system serves 3,945 residents in COLLINSVILLE. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans