

MILLBROOK UTILITIES

MILLBROOK, AL | PWSID: AL0000539 | Population served: 5,451

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



PFOS exceeds the federal limit at 3.56x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	14.2	4.0	3.56	EXCEEDS
PFOA	13.7	4.0	3.42	EXCEEDS
PFBS	57.1	-	-	No federal limit
PFPeA	21.1	-	-	No federal limit
PFHxA	13.5	-	-	No federal limit
PFBA	8.5	-	-	No federal limit
PFHpA	5.2	-	-	No federal limit

What This Means

This water system serves 5,451 residents in MILLBROOK. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans