

## WILCOX COUNTY WATER AUTHORITY

CAMDEN, AL | PWSID: AL0001371 | Population served: 6,144  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 3.04x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	12.2	4.0	3.04	<b>EXCEEDS</b>
PFOA	8.7	4.0	2.17	<b>EXCEEDS</b>
PFBS	30.2	-	-	No federal limit
PFPeA	11.7	-	-	No federal limit
PFHxA	7.8	-	-	No federal limit
PFBA	5.8	-	-	No federal limit
PFHpA	3.9	-	-	No federal limit

### What This Means

This water system serves 6,144 residents in CAMDEN. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans