

## PAYSON TOWN OF

PAYSON, AZ | PWSID: AZ0404032 | Population served: 17,682

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 4.79x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	19.2	4.0	4.79	<b>EXCEEDS</b>
PFOA	18.9	4.0	4.72	<b>EXCEEDS</b>
PFHxS	10.3	10.0	1.03	<b>EXCEEDS</b>
PFBS	17.4	-	-	No federal limit
PFBA	13.4	-	-	No federal limit
PFPeA	12.8	-	-	No federal limit
PFHxA	11.7	-	-	No federal limit
PFHpA	5.9	-	-	No federal limit
PFDA	3.4	-	-	No federal limit

### What This Means

This water system serves 17,682 residents in PAYSON. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans