

EL MIRAGE CITY OF

EL MIRAGE, AZ | PWSID: AZ0407091 | Population served: 39,884
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



PFOA detected at 100% of the federal limit, approaching the threshold

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	4.0	4.0	1.00	Below limit
PFPeA	9.9	-	-	No federal limit
PFBS	8.8	-	-	No federal limit
PFHxA	5.8	-	-	No federal limit

What This Means

This water system serves 39,884 residents in EL MIRAGE. EPA testing detected 29 PFAS compounds, 0 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans