

## GILBERT, TOWN OF

GILBERT, AZ | PWSID: AZ0407092 | Population served: 247,600

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 1.93x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	7.7	4.0	1.93	<b>EXCEEDS</b>
PFOA	6.5	4.0	1.63	<b>EXCEEDS</b>
PFBS	11.7	-	-	No federal limit
PFBA	5.4	-	-	No federal limit
PFPeA	4.8	-	-	No federal limit
PFHxA	4.4	-	-	No federal limit

### What This Means

This water system serves 247,600 residents in GILBERT. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans