

## COMPTON-CITY, WATER DEPT.

COMPTON, CA | PWSID: CA1910026 | Population served: 74,877  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 3.88x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	15.5	4.0	3.88	<b>EXCEEDS</b>
PFOA	4.9	4.0	1.23	<b>EXCEEDS</b>
PFHxS	4.0	10.0	0.41	Below limit

### What This Means

This water system serves 74,877 residents in COMPTON. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans