

LA HABRA HEIGHTS CWD

LA HABRA HEIGHTS, CA | PWSID: CA1910218 | Population served: 5,325

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



PFOS severely exceeds the federal limit at 5.69x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status |
|----------|----------------|-----------------|-------|------------------|
| PFOS | 22.8 | 4.0 | 5.69 | EXCEEDS |
| PFOA | 10.6 | 4.0 | 2.64 | EXCEEDS |
| PFHxS | 4.4 | 10.0 | 0.44 | Below limit |
| PFPeA | 9.7 | - | - | No federal limit |
| PFBA | 8.2 | - | - | No federal limit |
| PFHxA | 7.8 | - | - | No federal limit |
| PFBS | 7.6 | - | - | No federal limit |

What This Means

This water system serves 5,325 residents in LA HABRA HEIGHTS. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans