

## CITY OF ATWATER

ATWATER, CA | PWSID: CA2410001 | Population served: 29,479

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS severely exceeds the federal limit at 5.71x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	22.8	4.0	5.71	EXCEEDS
PFOA	17.9	4.0	4.47	EXCEEDS
PFHxS	15.5	10.0	1.55	EXCEEDS
6:2FTS	13.0	-	-	No federal limit
PFHxA	10.1	-	-	No federal limit
PFBA	9.5	-	-	No federal limit
PFPeA	9.1	-	-	No federal limit
PFHpA	6.6	-	-	No federal limit
PFPeS	6.2	-	-	No federal limit
PFBS	5.1	-	-	No federal limit

### What This Means

This water system serves 29,479 residents in ATWATER. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans