

## CITY OF GARDEN GROVE

GARDEN GROVE, CA | PWSID: CA3010062 | Population served: 174,226

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 3.40x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	13.6	4.0	3.40	<b>EXCEEDS</b>
PFOA	7.4	4.0	1.84	<b>EXCEEDS</b>
PFHxS	8.0	10.0	0.80	Below limit
PFBA	7.8	-	-	No federal limit
PFPeA	5.8	-	-	No federal limit
PFHxA	4.0	-	-	No federal limit

### What This Means

This water system serves 174,226 residents in GARDEN GROVE. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans