

## CITY OF SACRAMENTO MAIN

SACRAMENTO, CA | PWSID: CA3410020 | Population served: 520,407  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS severely exceeds the federal limit at 5.42x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	21.7	4.0	5.42	<b>EXCEEDS</b>
PFOA	16.4	4.0	4.11	<b>EXCEEDS</b>
PFHxS	10.2	10.0	1.02	<b>EXCEEDS</b>
PFBA	7.2	-	-	No federal limit
PFHxA	6.0	-	-	No federal limit
PFPeA	5.3	-	-	No federal limit
PFBS	5.0	-	-	No federal limit
PFHpA	4.3	-	-	No federal limit

### What This Means

This water system serves 520,407 residents in SACRAMENTO. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans