

## ONTARIO MUNICIPAL UTILITIES COMPANY

ONTARIO, CA | PWSID: CA3610034 | Population served: 185,010

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOA severely exceeds the federal limit at 7.50x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	30.0	4.0	7.50	<b>EXCEEDS</b>
PFOS	5.2	4.0	1.30	<b>EXCEEDS</b>
PFHxS	4.2	10.0	0.42	Below limit
PFHxA	7.1	-	-	No federal limit
PFBA	6.3	-	-	No federal limit
PFPeA	5.8	-	-	No federal limit

### What This Means

This water system serves 185,010 residents in ONTARIO. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans