

POTRERO ELEMENTARY SCHOOL

PINE VALLEY, CA | PWSID: CA3700963 | Population served: 300
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



PFOA severely exceeds the federal limit at 45.35x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	181.4	4.0	45.35	EXCEEDS
PFHxS	221.9	10.0	22.20	EXCEEDS
PFOS	57.1	4.0	14.29	EXCEEDS
PFNA	9.3	10.0	0.93	Below limit
PFHxA	77.2	-	-	No federal limit
PFHpA	60.4	-	-	No federal limit
PFPeA	48.9	-	-	No federal limit
PFBA	11.3	-	-	No federal limit
PFBS	5.3	-	-	No federal limit

What This Means

This water system serves 300 residents in PINE VALLEY. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans