

## SNAKE RIVER WD

KEYSTONE, CO | PWSID: CO0159105 | Population served: 9,900

Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS exceeds the federal limit at 4.38x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	17.5	4.0	4.38	<b>EXCEEDS</b>
PFOA	5.8	4.0	1.45	<b>EXCEEDS</b>
PFHxS	11.2	10.0	1.11	<b>EXCEEDS</b>
PFPeA	6.6	-	-	No federal limit
PFBS	5.8	-	-	No federal limit
PFHxA	4.8	-	-	No federal limit
PFHpA	4.2	-	-	No federal limit

### What This Means

This water system serves 9,900 residents in KEYSTONE. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans