

## LOCHBUIE TOWN OF

LOCHBUIE, CO | PWSID: CO0162486 | Population served: 6,830  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFAS detected below federal limits

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFHxS	3.0	10.0	0.30	Below limit
PFPeA	6.8	-	-	No federal limit
PFHxA	5.6	-	-	No federal limit
PFBS	4.8	-	-	No federal limit

### What This Means

This water system serves 6,830 residents in LOCHBUIE. EPA testing detected 29 PFAS compounds, 0 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans