

## AQUARION WATER CO OF CT-VALLEY SYSTEM

SHELTON, CT | PWSID: CT1240011 | Population served: 13,080

Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOA exceeds the federal limit at 1.40x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status           |
|----------|----------------|-----------------|-------|------------------|
| PFOA     | 5.6            | 4.0             | 1.40  | <b>EXCEEDS</b>   |
| PFOS     | 5.2            | 4.0             | 1.29  | <b>EXCEEDS</b>   |
| PFPeA    | 5.2            | -               | -     | No federal limit |
| PFHxA    | 3.8            | -               | -     | No federal limit |
| PFBS     | 3.8            | -               | -     | No federal limit |
| PFHpA    | 3.6            | -               | -     | No federal limit |

### What This Means

This water system serves 13,080 residents in SHELTON. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans