

## ARTESIAN WATER COMPANY

NEWARK, DE | PWSID: DE0000552 | Population served: 231,114

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOA exceeds the federal limit at 2.62x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	10.5	4.0	2.62	<b>EXCEEDS</b>
PFOS	5.5	4.0	1.39	<b>EXCEEDS</b>
PFHxS	6.7	10.0	0.67	Below limit
PFBA	30.7	-	-	No federal limit
PFPeA	26.9	-	-	No federal limit
PFHxA	12.9	-	-	No federal limit
PFHpA	8.5	-	-	No federal limit
PFBS	4.9	-	-	No federal limit

### What This Means

This water system serves 231,114 residents in NEWARK. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans