Water Quality Report Card

CheckYourWater.org

GEORGETOWN WATER DEPARTMENT

GEORGETOWN, DE | PWSID: DE0000592 | Population served: 7,259

Based on EPA UCMR 5 testing data (2023-2025) | Report generated November 25, 2026

D

PFOA exceeds the federal limit at 4.92x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	19.7	4.0	4.92	**EXCEEDS**
PFOS	11.0	4.0	2.76	**EXCEEDS**
PFNA	18.3	10.0	1.83	**EXCEEDS**
PFHxS	5.0	10.0	0.51	Below limit
6:2FTS	180.0	-	-	No federal limit
PFPeA	39.7	-	-	No federal limit
8:2FTS	30.0	-	-	No federal limit
PFHxA	25.9	-	-	No federal limit
PFBA	24.0	-	-	No federal limit
PFHpA	16.1	-	-	No federal limit
PFBS	7.5	-	-	No federal limit

What This Means

This water system serves 7,259 residents in GEORGETOWN. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans

This report is provided for informational purposes. It is not a substitute for professional water quality analysis.