

## LADY LAKE CENTRAL - WPS 1,2,3

LADY LAKE, FL | PWSID: FL3350977 | Population served: 7,090

Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS severely exceeds the federal limit at 8.10x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	32.4	4.0	8.10	<b>EXCEEDS</b>
PFHxS	13.6	10.0	1.36	<b>EXCEEDS</b>
PFOA	4.8	4.0	1.20	<b>EXCEEDS</b>
PFNA	4.0	10.0	0.40	Below limit
PFBS	8.7	-	-	No federal limit
PFPeA	6.7	-	-	No federal limit
PFHxA	5.9	-	-	No federal limit
PFHpA	3.5	-	-	No federal limit

### What This Means

This water system serves 7,090 residents in LADY LAKE. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans