

## BCWWS 2A

POMPANO BEACH, FL | PWSID: FL4060163 | Population served: 54,622

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS severely exceeds the federal limit at 6.50x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	26.0	4.0	6.50	<b>EXCEEDS</b>
PFOA	9.7	4.0	2.42	<b>EXCEEDS</b>
PFHxS	5.0	10.0	0.49	Below limit
PFPeA	12.8	-	-	No federal limit
PFHxA	10.6	-	-	No federal limit
PFBA	8.0	-	-	No federal limit
6:2FTS	7.1	-	-	No federal limit
PFBS	6.8	-	-	No federal limit
PFHpA	5.2	-	-	No federal limit

### What This Means

This water system serves 54,622 residents in POMPANO BEACH. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans