

## LAUDERHILL, CITY OF

LAUDERHILL, FL | PWSID: FL4060787 | Population served: 55,000  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS severely exceeds the federal limit at 8.63x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	34.5	4.0	8.63	<b>EXCEEDS</b>
PFOA	10.1	4.0	2.51	<b>EXCEEDS</b>
PFHxS	7.8	10.0	0.78	Below limit
PFPeA	10.8	-	-	No federal limit
PFHxA	7.8	-	-	No federal limit
PFBS	7.0	-	-	No federal limit
PFBA	5.8	-	-	No federal limit
PFHpA	4.8	-	-	No federal limit

### What This Means

This water system serves 55,000 residents in LAUDERHILL. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans