

## PEMBROKE PINES, CITY OF

PEMBROKE PINES, FL | PWSID: FL4061083 | Population served: 187,459

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS severely exceeds the federal limit at 7.25x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	29.0	4.0	7.25	<b>EXCEEDS</b>
PFOA	12.3	4.0	3.08	<b>EXCEEDS</b>
PFHxS	7.6	10.0	0.76	Below limit
6:2FTS	33.5	-	-	No federal limit
PFPeA	20.8	-	-	No federal limit
PFHxA	15.9	-	-	No federal limit
PFBA	10.7	-	-	No federal limit
PFBS	8.4	-	-	No federal limit
PFHpA	8.3	-	-	No federal limit

### What This Means

This water system serves 187,459 residents in PEMBROKE PINES. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans