

POMPANO BEACH, CITY OF

POMPANO BEACH, FL | PWSID: FL4061129 | Population served: 99,400

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



PFOS exceeds the federal limit at 4.38x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	17.5	4.0	4.38	EXCEEDS
PFOA	6.6	4.0	1.65	EXCEEDS
PFHxS	4.7	10.0	0.47	Below limit
6:2FTS	62.0	-	-	No federal limit
PFHxA	25.0	-	-	No federal limit
PFBA	19.0	-	-	No federal limit
PFPeA	13.7	-	-	No federal limit
PFHpA	9.6	-	-	No federal limit
PFBS	4.3	-	-	No federal limit

What This Means

This water system serves 99,400 residents in POMPANO BEACH. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans