

## HIALEAH, CITY OF

HIALEAH, FL | PWSID: FL4130604 | Population served: 238,000

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 4.88x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	19.5	4.0	4.88	<b>EXCEEDS</b>
PFOA	9.0	4.0	2.25	<b>EXCEEDS</b>
PFHxS	6.0	10.0	0.60	Below limit
PFNA	4.3	10.0	0.43	Below limit
6:2FTS	76.8	-	-	No federal limit
PFPeA	20.2	-	-	No federal limit
PFHxA	19.1	-	-	No federal limit
PFHpA	14.3	-	-	No federal limit
PFBA	14.1	-	-	No federal limit
8:2FTS	5.5	-	-	No federal limit
PFBS	4.1	-	-	No federal limit

### What This Means

This water system serves 238,000 residents in HIALEAH. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans