

## MDWASA - MAIN SYSTEM

MIAMI, FL | PWSID: FL4130871 | Population served: 2,377,460

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 4.75x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	19.0	4.0	4.75	<b>EXCEEDS</b>
PFOA	7.2	4.0	1.80	<b>EXCEEDS</b>
PFHxS	6.9	10.0	0.69	Below limit
PFNA	5.6	10.0	0.56	Below limit
6:2FTS	108.9	-	-	No federal limit
PFPeA	23.4	-	-	No federal limit
PFHxA	23.1	-	-	No federal limit
PFBA	13.6	-	-	No federal limit
PFHpA	10.1	-	-	No federal limit
8:2FTS	8.9	-	-	No federal limit
PFBS	4.1	-	-	No federal limit

### What This Means

This water system serves 2,377,460 residents in MIAMI. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans