

## MIAMI BEACH, CITY OF

MIAMI BEACH, FL | PWSID: FL4130901 | Population served: 100,000  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS severely exceeds the federal limit at 6.00x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	24.0	4.0	6.00	<b>EXCEEDS</b>
PFOA	7.8	4.0	1.95	<b>EXCEEDS</b>
PFHxS	5.6	10.0	0.56	Below limit
6:2FTS	89.0	-	-	No federal limit
PFHxA	28.0	-	-	No federal limit
PFPeA	27.0	-	-	No federal limit
PFBA	15.0	-	-	No federal limit
PFHpA	11.0	-	-	No federal limit
8:2FTS	5.3	-	-	No federal limit
PFBS	3.5	-	-	No federal limit

### What This Means

This water system serves 100,000 residents in MIAMI BEACH. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans