

NORTH BAY VILLAGE, CITY OF

NORTH BAY VILLAGE, FL | PWSID: FL4130970 | Population served: 8,317

Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



PFOS severely exceeds the federal limit at 7.61x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	30.4	4.0	7.61	EXCEEDS
PFOA	9.9	4.0	2.48	EXCEEDS
PFHxS	6.7	10.0	0.67	Below limit
PFNA	5.6	10.0	0.56	Below limit
6:2FTS	96.3	-	-	No federal limit
PFHxA	36.3	-	-	No federal limit
PFPeA	32.8	-	-	No federal limit
PFBA	15.8	-	-	No federal limit
PFHpA	14.1	-	-	No federal limit
8:2FTS	10.7	-	-	No federal limit
PFBS	5.0	-	-	No federal limit

What This Means

This water system serves 8,317 residents in NORTH BAY VILLAGE. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans