

## LANTANA WATER TREATMENT PLANT

LANTANA, FL | PWSID: FL4500784 | Population served: 11,558

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS severely exceeds the federal limit at 8.34x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	33.4	4.0	8.34	<b>EXCEEDS</b>
PFOA	11.3	4.0	2.83	<b>EXCEEDS</b>
PFHxS	7.3	10.0	0.73	Below limit
PFNA	6.5	10.0	0.65	Below limit
PFPeA	12.3	-	-	No federal limit
PFBA	10.1	-	-	No federal limit
PFHxA	10.1	-	-	No federal limit
PFBS	9.9	-	-	No federal limit
PFHpA	5.5	-	-	No federal limit

### What This Means

This water system serves 11,558 residents in LANTANA. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans