

## RIVIERA BEACH UTILITY DISTRICT, CITY OF

RIVIERA BEACH, FL | PWSID: FL4501229 | Population served: 46,762  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS severely exceeds the federal limit at 6.75x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	27.0	4.0	6.75	<b>EXCEEDS</b>
PFOA	13.5	4.0	3.38	<b>EXCEEDS</b>
PFHxS	7.0	10.0	0.70	Below limit
PFPeA	6.9	-	-	No federal limit
PFHxA	5.8	-	-	No federal limit
PFHpA	4.2	-	-	No federal limit
PFBS	3.5	-	-	No federal limit

### What This Means

This water system serves 46,762 residents in RIVIERA BEACH. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans