

## CLAYTON COUNTY WATER AUTHORITY

MORROW, GA | PWSID: GA0630000 | Population served: 298,374

Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS exceeds the federal limit at 1.71x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	6.8	4.0	1.71	<b>EXCEEDS</b>
PFOA	6.3	4.0	1.57	<b>EXCEEDS</b>
PFHxS	4.2	10.0	0.42	Below limit
PFHxA	9.7	-	-	No federal limit
PFPeA	9.6	-	-	No federal limit
PFBA	5.9	-	-	No federal limit
6:2FTS	5.3	-	-	No federal limit
PFBS	5.2	-	-	No federal limit
PFHpA	4.4	-	-	No federal limit

### What This Means

This water system serves 298,374 residents in MORROW. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans