

## SIOUX CITY WATER SUPPLY

SIOUX CITY, IA | PWSID: IA9778054 | Population served: 85,791

Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFHxS exceeds the federal limit at 3.02x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFHxS	30.3	10.0	3.02	<b>EXCEEDS</b>
PFOA	5.7	4.0	1.43	<b>EXCEEDS</b>
PFOS	4.2	4.0	1.05	<b>EXCEEDS</b>
PFHxA	21.9	-	-	No federal limit
PFPeA	19.0	-	-	No federal limit
PFBS	18.0	-	-	No federal limit
PFPeS	11.3	-	-	No federal limit
PFBA	7.8	-	-	No federal limit
PFHpA	4.1	-	-	No federal limit

### What This Means

This water system serves 85,791 residents in SIOUX CITY. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans