

## CAPITOL WATER CORP

BOISE, ID | PWSID: ID4010022 | Population served: 9,000

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFNA exceeds the federal limit at 2.16x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFNA	21.6	10.0	2.16	<b>EXCEEDS</b>
PFOS	6.8	4.0	1.71	<b>EXCEEDS</b>
PFOA	5.8	4.0	1.45	<b>EXCEEDS</b>
PFHxS	4.7	10.0	0.47	Below limit
PFPeA	5.1	-	-	No federal limit
PFHxA	4.9	-	-	No federal limit
PFBS	4.0	-	-	No federal limit

### What This Means

This water system serves 9,000 residents in BOISE. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans