

## GARDEN CITY WATER AND SEWER SYSTEM

GARDEN CITY, ID | PWSID: ID4010066 | Population served: 12,500

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS severely exceeds the federal limit at 6.38x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	25.5	4.0	6.38	<b>EXCEEDS</b>
PFHxS	13.8	10.0	1.38	<b>EXCEEDS</b>
PFNA	7.5	10.0	0.76	Below limit
PFBS	5.8	-	-	No federal limit
PFHxA	5.5	-	-	No federal limit
PFPeA	4.5	-	-	No federal limit
PFPeS	4.4	-	-	No federal limit

### What This Means

This water system serves 12,500 residents in GARDEN CITY. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans