# Water Quality Report Card

CheckYourWater.org

## JASPER MUNICIPAL WATER UTILITY

JASPER, IN | PWSID: IN5219009 | Population served: 17,440

Based on EPA UCMR 5 testing data (2023-2025) | Report generated November 25, 2026

**B**

### PFAS detected below federal limits

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

## Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status |
|---|---|---|---|---|
| PFBA | 5.2 | - | - | No federal limit |

## What This Means

This water system serves 17,440 residents in JASPER. EPA testing detected 29 PFAS compounds, 0 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

## What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans



This report is provided for informational purposes. It is not a substitute for professional water quality analysis.