

## PIKE-GIBSON WATER, INC.

OAKLAND CITY, IN | PWSID: IN5263003 | Population served: 10,000  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOA exceeds the federal limit at 1.98x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	7.9	4.0	1.98	<b>EXCEEDS</b>
HFPO-DA	5.3	10.0	0.53	Below limit
PFBA	8.8	-	-	No federal limit
PFPeA	4.3	-	-	No federal limit
PFBS	3.5	-	-	No federal limit

### What This Means

This water system serves 10,000 residents in OAKLAND CITY. EPA testing detected 29 PFAS compounds, 1 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans