

## SOUTH BEND WATER WORKS

SOUTH BEND, IN | PWSID: IN5271014 | Population served: 115,000  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOA exceeds the federal limit at 1.85x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	7.4	4.0	1.85	<b>EXCEEDS</b>
PFHxS	8.3	10.0	0.83	Below limit
PFPeA	14.2	-	-	No federal limit
PFBA	12.5	-	-	No federal limit
PFHxA	10.6	-	-	No federal limit
PFHpA	8.3	-	-	No federal limit
PFPeS	7.2	-	-	No federal limit
PFBS	5.0	-	-	No federal limit

### What This Means

This water system serves 115,000 residents in SOUTH BEND. EPA testing detected 29 PFAS compounds, 1 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans