

## FRUSI WATER TREATMENT PLANT

FORT RILEY, KS | PWSID: KS2006114 | Population served: 35,784  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOA exceeds the federal limit at 3.52x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	14.1	4.0	3.52	EXCEEDS
PFOS	8.8	4.0	2.20	EXCEEDS
PFHxS	18.8	10.0	1.88	EXCEEDS
PFPeA	11.3	-	-	No federal limit
PFHxA	7.2	-	-	No federal limit
PFBS	6.5	-	-	No federal limit
PFPeS	4.3	-	-	No federal limit

### What This Means

This water system serves 35,784 residents in FORT RILEY. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans