

## JOHNSON CO RWD 7

GARDNER, KS | PWSID: KS2009104 | Population served: 6,457

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFAS detected below federal limits

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status           |
|----------|----------------|-----------------|-------|------------------|
| PFBA     | 7.1            | -               | -     | No federal limit |

### What This Means

This water system serves 6,457 residents in GARDNER. EPA testing detected 29 PFAS compounds, 0 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans