

## CITY OF VIDALIA WATER SYSTEM

VIDALIA, LA | PWSID: LA1029011 | Population served: 6,354

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOA severely exceeds the federal limit at 5.03x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	20.1	4.0	5.03	<b>EXCEEDS</b>
PFOS	7.3	4.0	1.82	<b>EXCEEDS</b>
PFNA	4.8	10.0	0.48	Below limit
PFBA	31.7	-	-	No federal limit
PFPeA	12.9	-	-	No federal limit
PFHxA	10.8	-	-	No federal limit
PFBS	3.5	-	-	No federal limit
PFHpA	3.2	-	-	No federal limit

### What This Means

This water system serves 6,354 residents in VIDALIA. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans