

## SHARON WATER DEPT

SHARON, MA | PWSID: MA4266000 | Population served: 16,991

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 2.27x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	9.1	4.0	2.27	<b>EXCEEDS</b>
PFHxS	20.5	10.0	2.05	<b>EXCEEDS</b>
PFOA	6.5	4.0	1.63	<b>EXCEEDS</b>
PFHxA	5.0	-	-	No federal limit
PFPeA	4.9	-	-	No federal limit
PFBS	4.4	-	-	No federal limit

### What This Means

This water system serves 16,991 residents in SHARON. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans