

## TOWN OF MIDDLETOWN

MIDDLETOWN, MD | PWSID: MD0100018 | Population served: 4,288  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 1.52x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	6.1	4.0	1.52	<b>EXCEEDS</b>
PFOA	4.5	4.0	1.13	<b>EXCEEDS</b>
PFHxS	3.4	10.0	0.34	Below limit
PFPeA	7.2	-	-	No federal limit
PFBA	5.1	-	-	No federal limit
PFBS	4.9	-	-	No federal limit
PFHxA	4.8	-	-	No federal limit
PFHpA	3.0	-	-	No federal limit

### What This Means

This water system serves 4,288 residents in MIDDLETOWN. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans