

WATERFORD TOWNSHIP

WATERFORD, MI | PWSID: MI0006910 | Population served: 73,441
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



PFHxS detected at 65% of the federal limit, approaching the threshold

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status |
|----------|----------------|-----------------|-------|-------------|
| PFHxS | 6.5 | 10.0 | 0.65 | Below limit |

What This Means

This water system serves 73,441 residents in WATERFORD. EPA testing detected 29 PFAS compounds, 0 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans