

## CITY OF OXFORD

OXFORD, MS | PWSID: MS0360011 | Population served: 28,500  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS severely exceeds the federal limit at 13.24x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	53.0	4.0	13.24	<b>EXCEEDS</b>
PFOA	4.3	4.0	1.09	<b>EXCEEDS</b>
PFHxS	6.8	10.0	0.69	Below limit
6:2FTS	20.7	-	-	No federal limit
PFPeA	11.6	-	-	No federal limit
PFHxA	7.9	-	-	No federal limit
PFBS	6.5	-	-	No federal limit
PFBA	5.6	-	-	No federal limit
PFHpA	3.2	-	-	No federal limit

### What This Means

This water system serves 28,500 residents in OXFORD. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans