

## GREENSBORO, CITY OF

GREENSBORO, NC | PWSID: NC0241010 | Population served: 319,588

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS severely exceeds the federal limit at 5.68x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	22.7	4.0	5.68	EXCEEDS
PFOA	4.9	4.0	1.22	EXCEEDS
PFHxS	11.2	10.0	1.12	EXCEEDS
6:2FTS	7.2	-	-	No federal limit
PFBA	6.7	-	-	No federal limit
PFHxA	6.4	-	-	No federal limit
PFPeA	5.9	-	-	No federal limit
PFBS	4.0	-	-	No federal limit
PFHpA	3.8	-	-	No federal limit

### What This Means

This water system serves 319,588 residents in GREENSBORO. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans