

## OAK ISLAND, TOWN OF

OAK ISLAND, NC | PWSID: NC0410020 | Population served: 26,924

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 2.88x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	11.5	4.0	2.88	<b>EXCEEDS</b>
PFOA	6.9	4.0	1.73	<b>EXCEEDS</b>
HFPO-DA	5.2	10.0	0.52	Below limit
PFHxS	4.7	10.0	0.47	Below limit
PFPeA	10.0	-	-	No federal limit
PFHxA	8.7	-	-	No federal limit
PFBA	6.6	-	-	No federal limit
PFBS	5.6	-	-	No federal limit
PFHpA	3.9	-	-	No federal limit

### What This Means

This water system serves 26,924 residents in OAK ISLAND. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans