

## NASHVILLE, TOWN OF

NASHVILLE, NC | PWSID: NC0464020 | Population served: 5,900  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS severely exceeds the federal limit at 25.86x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	103.4	4.0	25.86	<b>EXCEEDS</b>
PFHxS	26.5	10.0	2.65	<b>EXCEEDS</b>
PFOA	5.9	4.0	1.49	<b>EXCEEDS</b>
PFHxA	4.6	-	-	No federal limit
PFHpS	3.6	-	-	No federal limit
PFBS	3.5	-	-	No federal limit

### What This Means

This water system serves 5,900 residents in NASHVILLE. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans