

GRASSY POND WATER CORPORATION

GAFFNEY, NC | PWSID: NC2023003 | Population served: 1,303

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



PFOS exceeds the federal limit at 3.75x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	15.0	4.0	3.75	EXCEEDS
PFOA	12.5	4.0	3.13	EXCEEDS
PFHxS	4.5	10.0	0.45	Below limit
PFPeA	5.8	-	-	No federal limit
PFHxA	4.8	-	-	No federal limit
PFHpA	4.6	-	-	No federal limit
PFBS	3.3	-	-	No federal limit

What This Means

This water system serves 1,303 residents in GAFFNEY. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans