

## WALDWICK WATER DEPT

WALDWICK, NJ | PWSID: NJ0264001 | Population served: 10,208  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOA severely exceeds the federal limit at 5.30x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	21.2	4.0	5.30	<b>EXCEEDS</b>
PFOS	9.4	4.0	2.36	<b>EXCEEDS</b>
PFNA	5.0	10.0	0.49	Below limit
PFHxS	3.9	10.0	0.39	Below limit
PFPeA	10.8	-	-	No federal limit
PFBA	10.4	-	-	No federal limit
PFHxA	9.9	-	-	No federal limit
PFHpA	6.1	-	-	No federal limit
PFBS	5.4	-	-	No federal limit

### What This Means

This water system serves 10,208 residents in WALDWICK. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans