

## MT LAUREL TWP MUA

MIOUNT LAUREL, NJ | PWSID: NJ0324001 | Population served: 41,743  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 2.08x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	8.3	4.0	2.08	<b>EXCEEDS</b>
PFOA	4.5	4.0	1.13	<b>EXCEEDS</b>
PFHxS	5.2	10.0	0.52	Below limit

### What This Means

This water system serves 41,743 residents in MIOUNT LAUREL. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans